

# Detailed Latest Test Results

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 4/06/2007 To: 4/08/2014

Insulation	3/07/2009	>99.99	MOhm	Pass
Class I Leakage	3/07/2009	<0.1	mA	Pass

Overall: Pass

Asset ID: 403	Description: Heater	User: STEVEB	Test Instrument: U02-0427
Comments: OK			

Test Type	Date	Result	Unit	Status
Visual (Plugs)	3/07/2009			Pass
Visual (Flexible Cord)	3/07/2009			Pass
Visual (Cover / Guards)	3/07/2009			Pass
Earth Current	3/07/2009	100	mA a.c.	Information
Earth	3/07/2009	0.19	Ohm	Pass
Insulation	3/07/2009	>99.99	MOhm	Pass

Overall: Pass

Asset ID: 404	Description: Computer	User: STEVEB	Test Instrument: U02-0427
Comments: OK			

Test Type	Date	Result	Unit	Status
Visual (Plugs)	3/07/2009			Pass
Visual (Flexible Cord)	3/07/2009			Pass
Visual (Cover / Guards)	3/07/2009			Pass
Earth Current	3/07/2009	100	mA a.c.	Information
Earth	3/07/2009	0.1	Ohm	Pass
Insulation	3/07/2009	>99.99	MOhm	Pass

Overall: Pass

Asset ID: 405	Description: Monitor	User: STEVEB	Test Instrument: U02-0427
Comments: OK			

Test Type	Date	Result	Unit	Status
Visual (Plugs)	3/07/2009			Pass
Visual (Flexible Cord)	3/07/2009			Pass
Visual (Cover / Guards)	3/07/2009			Pass
Earth Current	3/07/2009	100	mA a.c.	Information
Earth	3/07/2009	0.1	Ohm	Pass
Insulation	3/07/2009	>99.99	MOhm	Pass

Overall: Pass

Asset ID: 406	Description: Computer Lead	User: STEVEB	Test Instrument: U02-0427
Comments: OK			

Test Type	Date	Result	Unit	Status
Visual (Plugs)	3/07/2009			Pass
Visual (Flexible Cord)	3/07/2009			Pass
Visual (Cover / Guards)	3/07/2009			Pass
Earth Current	3/07/2009	25	A	Information
Earth	3/07/2009	0.1	Ohm	Pass
Insulation	3/07/2009	>99.99	MOhm	Pass
Polarity	3/07/2009			Pass

Overall: Pass

Asset ID: 407	Description: Computer Lead	User: STEVEB	Test Instrument: U02-0427
Comments: OK			

Test Type	Date	Result	Unit	Status
Visual (Plugs)	3/07/2009			Pass
Visual (Flexible Cord)	3/07/2009			Pass
Visual (Cover / Guards)	3/07/2009			Pass
Earth Current	3/07/2009	25	A	Information
Earth	3/07/2009	0.1	Ohm	Pass
Insulation	3/07/2009	>99.99	MOhm	Pass
Polarity	3/07/2009			Pass

Overall: Pass

Asset ID: 408	Description: Epod	User: STEVEB	Test Instrument: U02-0427
Comments: OK			

Test Type	Date	Result	Unit	Status
Visual (Plugs)	3/07/2009			Pass
Visual (Flexible Cord)	3/07/2009			Pass
Visual (Cover / Guards)	3/07/2009			Pass
Earth Current	3/07/2009	25	A	Information
Earth	3/07/2009	0.1	Ohm	Pass
Earth	3/07/2009	0.1	Ohm	Pass
Earth	3/07/2009	0.1	Ohm	Pass
Earth	3/07/2009	0.1	Ohm	Pass

This document was created with Win2PDF available at <http://www.win2pdf.com>.  
The unregistered version of Win2PDF is for evaluation or non-commercial use only.  
This page will not be added after purchasing Win2PDF.